



SITE PLAN

1. Standard Reflectance of 80/50/20 unless noted otherwise
2. Not a Construction Document, for Design purposes only
3. Standard indoor calc points @ 30" A.F.F. unless noted otherwise
4. Standard outdoor calc points @ Grade unless noted otherwise
5. Mlazgar Associates assumes no responsibility for installed light levels due to field conditions, etc.

Calculation Summary							
Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min
CalcPts_1	Illuminance	Fc	0.52	11.1	0.0	N.A.	N.A.

Luminaire Schedule							
Symbol	Qty	Label	Description	Arrangement	Lum. Lumens	Lum. Watts	LLF
☐	7	AA	ALM 210 T3 G3 5K	SINGLE	21790	148.092	0.900
☐	2	BB	WMC 145 G1 5K	SINGLE	14500	125	0.900

SITE LIGHTING
ALL MAC
STACY, MN

RLMA Project #: 104091
Drawn By: BS
Date: 1/28/2021
Scale: 1" = 30'

Revisions

#	Date	Comments



MLAZGAR ASSOCIATES
10340 VIKING DR.
SUITE 150
EDEN PRAIRIE, MN 55344
(P) 952-943-8080
(F) 952-943-8088
www.mlazgar.com